



Features

- Universal AC input / Full range
- · Protections: Short circuit / Overload / Over voltage
- Battery low protection / Battery reverse polarity protection by fuse
- Can be installed on DIN rail TS-35/7.5 or 15
- Alarm signal for AC OK and Battery low (via TTL open collector, optional via relay)
- · Cooling by free air convection
- Pass LPS
- · LED indicator for power on
- 100% full load burn-in test
- 3 years warranty


Applications

- · Security system
- · Emergency lighting system
- · Alarm system
- · DC UPS system
- · Central monitoring system
- Access systems

Description

DRC-40 is a 40W AC/DC DIN rail type security power supply series. In addition to the primary output, there is a charger output with a smaller rated current, enabling the backup power supply application the security access systems require. DRC-40 accepts the universal input between 90VAC and 264VAC, and supplies 13.8VDC and 27.6VDC at output, respectively. With the efficiency up to 87%, it can operate with air convection cooling under -30°C through 70° C. In addition to the key protection features such as overload protection, over voltage protection, battery low cut off, and battery reverse polarity protection (by fuse), the alarm signal for AC OK and battery low signaling is provided, via TTL open collector output for the standard model (via relay contact output as the optional model), to facilitate the system design.

Model Encoding





SPECIFICATION


		DRC-40A		DRC-40B	DRC-40B		
	OUTPUT NUMBER	CH1	CH2	CH1	CH2		
	DC VOLTAGE	13.8V	13.8V	27.6V	27.6V		
	RATED CURRENT	1.9A	1A	0.95A	0.5A		
	CURRENT RANGE	0 ~ 2.9A		0 ~ 1.45A			
	RATED POWER	40.02W		40.02W			
OUTPUT	RIPPLE & NOISE (max.) Note.2	120mVp-p		200mVp-p			
	VOLTAGE ADJ. RANGE	CH1:12 ~ 15V		CH1:24 ~ 30V			
	VOLTAGE TOLERANCE Note.3	±1.0%		±1.0%			
	LINE REGULATION	±0.5%		±0.5%			
	LOAD REGULATION	±0.5%		±0.5%			
	SETUP, RISE TIME Note.4	400ms, 50ms/230VAC	800ms, 50ms/115VAC	at full load			
	HOLD UP TIME (Typ.)	50ms/230VAC 10ms/115VAC at full load					
INPUT	VOLTAGE RANGE	90 ~ 264VAC 127 ~ 370VDC [DC input operation possible by connecting AC/L(+), AC/N(-)]					
	FREQUENCY RANGE	47 ~ 63Hz					
	EFFICIENCY (Typ.)	86%		87%			
	AC CURRENT (Typ.)	0.8A/115VAC 0.6A/2	30VAC	***			
	INRUSH CURRENT (Typ.)	COLD START 30A/115VAC 60A/230VAC					
	(.)	105 ~ 150% rated output power					
	OVERLOAD			ally after fault condition is	removed		
ROTECTION		Protection type: Hiccup mode, recovers automatically after fault condition is removed CH1:14.49 ~ 18.63V CH1:28.98 ~ 37.26V					
NOTECTION	OVER VOLTAGE	Protection type: Shut down o/p voltage, re-power on to recover					
	BATTERY CUT OFF	10±0.5V	The of protongs, to post of o	20±1V			
	AC OK		NITACT · AC OK · CUT OF		50\//30mA		
UNCTION		Open collector output, CONTACT : AC OK ; CUT OFF : AC Fail ; max. rating : 50V/30mA Open collector output, CUT OFF : Battery ; CONTACT : Battery Low ; max. rating : 50V/30mA					
ONOTION	BATTERY LOW						
	WORKING TEMP.	Battery low voltage : < 11V Battery low voltage : < 22V -30 ~ +70 °C (Refer to "Derating Curve")					
		20 ~ 90% RH non-condensing					
NVIDONMENT	WORKING HUMIDITY						
NVIKONWENI	STORAGE TEMP., HUMIDITY	-40 ~ +85°C, 10 ~ 95% RH					
	TEMP. COEFFICIENT	±0.03%/°C (0 ~ 55°C) on CH1 output					
	VIBRATION	10 ~ 500Hz, 2G 10min./1cycle, 60min. each along X, Y, Z axes					
	SAFETY STANDARDS	UL60950-1, TUV EN60950-1, EAC TP TC 004 approved					
AFETY &		I/P-0/P:3KVAC I/P-FG:2KVAC					
Note 5)	ISOLATION RESISTANCE	I/P-O/P, I/P-FG, O/P-FG:100M Ohms / 500VDC / 25°C / 70% RH					
	EMC EMISSION	Compliance to EN55032 (CISPR32) Class B, EN61000-3-2,-3, EAC TP TC 020					
	EMC IMMUNITY	Compliance to EN61000-4-2,3,4,5,6,8,11, EN55024, EN61204-3, light industry level, criteria A, EAC TP TC 020					
	MTBF	536.6K hrs min. MIL-HDBK-217F (25°C)					
OTHERS	DIMENSION	40*90*100mm (W*H*D)					
	PACKING	0.3Kg; 42pcs/13.6Kg/0.82CUFT					
ОТЕ	 All parameters NOT specially mentioned are measured at 230VAC input, rated load and 25°C of ambient temperature. Ripple & noise are measured at 20MHz of bandwidth by using a 12" twisted pair-wire terminated with a 0.1uf & 47uf parallel of 3. Tolerance: includes set up tolerance, line regulation and load regulation. Length of set up time is measured at cold first start. Turning ON/OFF the power supply may lead to increase of the set up time. The power supply is considered a component which will be installed into a final equipment. The final equipment must be reconcurrent it still meets EMC directives. For guidance on how to perform these EMC tests, please refer to "EMI testing of component supplies." (as available on http://www.meanwell.com) Installation clearances: 40mm on top, 20mm on the bottom, 5mm on the left and right side are recommended when loaded permanently with full power. In case the adjacent device is a heat source, 15mm clearance is recommended. 						

7. The ambient temperature derating of $3.5^{\circ}\text{C}/1000\text{m}$ with fanless models and of $5^{\circ}\text{C}/1000\text{m}$ with fan models for operating altitude higher

than 2000m(6500ft).



■ Block Diagram




■ Derating Curve

30 -20 0 15 30 40 50 55 60 70 (VERTICAL)

AMBIENT TEMPERATURE (°C)

■ Static Characteristics





■ Suggested Application

1.Backup connection for AC interruption

(1) Please refer to Fig1.1 for suggested connection.

The power supply charges the battery and provides energy to the load at the same time when AC mains is OK.

The battery starts to supply power to the load when AC mains fails.




Fig 1.1 Suggested system connection

2. Alarm signal for AC OK and battery low

- (1) Alarm signal is sent out through "AC OK" & "Battery Low" pins. (TTL open collector output is provided for standard model, and relay contact output is provided as optional model.)
- (2) An external voltage source is required for this function. The maximum applied voltage is 50V and the maximum sink current is 30mA. Please refer to Fig 2.2.
- $(3) \ Table 2.1 \ explains \ the \ alarm \ function \ built \ in \ the \ power \ supply$

Function Description		Output of alarm	
AC OK	The signal is "Low" when the power supply turns ON.	Low (0.3V max. at 30mA)	
ACOK	The signal turns to be "High" when the power supply turns OFF.	High or open (External applied voltage 50V max.)	
Battery Low	The signal is "Low" when the voltage of battery is under A:11V, B:22V.	Low (0.3V max. at 30mA)	
Dattery LOW	The signal is "High" when the voltage of battery is above A:11V, B:22V.	High or open (External applied voltage 50V max.)	

Table 2.1 Explanation of alarm signal

AC OK (Battery low)





Fig 2.2 Internal circuit of AC OK (Battery Low), via TTL open collector




■ Mechanical Specification


Case No.962A Unit:mm












Terminal Pin No. Assignment (TB1):

Pin No.	Assignment	
1	AC/L or DC+	
2	AC/N or DC-	
3	FG ÷	

Terminal Pin No. Assignment (TB2):

• , ,								
Assignment	Pin No.	Assignment						
-V	4	Bat						
+V	5,6	AC OK						
Bat. +	7,8	Bat. Low						
	-V +V	-V 4 +V 5,6						

■ Installation Instruction



This series fits DIN rail TS35/7.5 or TS35/15. For installation details, please refer to the Instruction manual.

■ Installation Manual

Please refer to: http://www.meanwell.com/manual.html

Back View