

RCC

{REGULATORY COMPLIANCE CERTIFICATE}

ISSUED TO
RIPBOX (PTY) LTD
IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

*PRODUCT: JUNCTIONBOX (RIPBOX) 2010 KBG;
Minimum temperature during installation: -5° C ; Protection against ingress of solid objects: IP2X
Protection against ingress of water: IPXO*

Test Laboratory:
TACS Laboratories (PTY) Ltd.

Test report no: TJ00246
RCC No: 1803049

[Signature]
NRCS - Electrotechnical General Manager.



In accordance to (Standards):
SANS 60670-1: 2016

Period of Validity
23/03/2018 to 23/03/2021

DATE

26/03/2018